

SC-23-0210-0001-99

SmartCell Dual Smoke/Heat Detector and Combined Sounder-Beacon (VAD Red Flash)

Overview

The SmartCell Dual Smoke / Heat Detector With Sounder is quick and easy to install and offers individual addressing at the SmartCell Control Panel.

Features include dual smoke and/or heat detection, integrated sounder with 32 tones, bidirectional 868 MHz communication, fire indication LED and an anti-tamper locking mechanism.

This device is third party certified and compatible with the full SmartCell product range.



Details

- Fully wireless
- Quick and easy to install
- Compact profile
- Flexible detection; smoke and/or heat
- 32 sounder tones
- Includes part 23 beacon
- Unique design
- Inbuilt locking mechanism

SC-23-0210-0001-99

SmartCell Dual Smoke/Heat Detector and Combined Sounder-Beacon (VAD Red Flash)

Technical specifications

General

Wireless frequency	868 MHz
Compatibility	SmartCell

Electrical

Batteries	3 x ER14505M 3.6 V lithium thionyl chloride batteries (Fanso or Titus)
-----------	--

Sounder

Output level	93 dB(A) at 1 m max.
Output level adjustment	High or low
Selectable tones	32

VAD

Colour	Red
Rating	C-3-9.5
Flash frequency	0.5 Hz (1 flash, every 2 seconds)

Physical

Physical dimensions	110 x 58 mm (Ø x D)
Net weight	0.2 kg
Colour	White
Mounting type	Ceiling mount

Environmental

Operating temperature	-10 to +55°C
Storage temperature	-10 to +30°C (with batteries) -10 to +55°C (without batteries)
Relative humidity	95% noncondensing max.
Environment	Indoor
IP rating	IP21C

Regulatory

Compliancy	CE
Certification	CPR
Standards	EN54-3 EN54-5 EN54-7 EN54-13 EN54-23 EN54-25

Detection

Sensitivity	Smoke: Normal, Normal+AVF. Heat: 58 °C, static (A2S), 58 °C rate of rise (A2R), 72 °C static (BS), 72 °C rate of rise (BR)
-------------	--



As a company of innovation, Carrier Fire & Security reserves the right to change product specifications without notice. For the latest product specifications, visit uk.firesecurityproducts.com online or contact your sales representative.

Last updated on 5 May 2023 - 10:37